

Comparison of Water Use Patterns In Comore Loma with Nearby Cities

		Average Daily Flow (gpm)	Maximum Day Flow (gpm)	Peak Hour Flow (gpm)	Reference
Falls Water Company (4,080 Equivelant Users, metered)	Total System Per User	2,285 0.56	6,560 1.61	8,512 2.09	Brief Facility Plan Update, 2013
City of Ririe (390 Equivelant Users, metered)	Total System Per User	290 0.74	827 2.12	1000 2.56	2014 Water Facility Planning Study
City of Iona (550 Equivelant Users, unmetered)	Total System Per User	583 1.06	1458 2.65	2332 4.24	2008 Facility Plan Amendment
Comore Loma (320 Users)	Total System Per User	901 2.82	3,846 12.02	4,650 14.53	2014 Water Facility Planning Study
How many times more water supply does Comore Loma provide to users compared to Falls Water Company?		5.0	7.5	7.0	
How many times more water supply does Comore Loma provide to users compared to Ririe?		3.8	5.7	5.7	
How many times more water supply does Comore Loma provide to users compared to Iona?		2.7	4.5	3.4	